

महाराष्ट्र राज्य सार्वजनिक आरोग्य सेवा

राज्य/प्रादेशिक/जिल्हा आरोग्य प्रयोगशाळा अहिल्यानगर

दूरध्वनी क्रमांक ०२४१ - २३५४०३८

पाणी नमुन्याचा सूक्ष्मजीवीय अहवाल

प्रति,

पाठविणाऱ्यांचे पत्र क्रमांक व दिनांक

प्रयोगशाळा संदर्भ क्रमांक

नमुना घेतल्याचा दिनांक

नमुना पोहचल्याचा दिनांक

परीक्षण सुरु केल्याचा दिनांक

:- जिजामाता इंग्लिश मेडियम स्कूल, संभमनेर
:- ०४/०७/२०२६ (५०६)
:- ४२/१०४

:- ०६/०७/२०२६
:- ०७/०७/२०२६

अ. क्र.	नमुन्याचे विवरण	परीक्षणाचे निष्कर्ष			इतर अभिप्राय
		प्रति १०० मि.ली. नमुन्यातील संभाव्य सूक्ष्मजंतूची संख्या			
		कोलीफॉर्मस	थर्मोटॉलरंट कोलीफॉर्मस	इ. कोलाय	
	जिजामाता इंग्लिश मेडियम स्कूल संभमनेर, अहिल्यानगर. स्थान: नळ पाणी नमुना ०० R.No.-४४६२१७५ Amount-६००/- Date-०७/०७/२०२६		—	—	पिण्यास योग्य S

अभिप्राय : पिण्यास अयोग्य पाण्यावर योग्य प्रमाणात क्लोरिनची प्रक्रिया केल्यानंतर व सूक्ष्मजीवीय पुनर्तपासणीनंतर पिण्यास योग्य असल्याची खात्री झाल्यानंतर ते पाणी पिण्यासाठी वापरता येईल.

अहवाल क्रमांक : ११५३

दिनांक :- १३/७/२६

अभिप्राय तारेने काढविल्याचा दिनांक :

प्रत सादर :

(१) जिल्हा आरोग्य अधिकारी, जिल्हा परिषद, जिल्हा

(२) शल्यचिकित्सक, जिल्हा रुग्णालय, जिल्हा

(३) तालुक आरोग्य अधिकारी पंचायत समिती

Agz
कनिष्ठ वैज्ञानिक अधिकारी
जिल्हा आरोग्य प्रयोग शाळा
अहिल्यानगर-४१४ ००१.

State / Regional / District / Public Health Laboratory A.nagar

E-mail-ID: dphlanr@gmail.com

Phone No.: 0241 -2354038

REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Date of Collection:-

Date of Receipt :- 7/7/26 Date of Examination :- 7/7/26

(All the Analytical Results are in mg./Litre except pH, Turbidity)

around.

Sr. No.	TEST PARAMETER	(1) F.W.	(2)	(3)	BIS Specification 10500: 2012 Normal Values	
					Desirable Limits	Permissible Limits
1.	Physical Appearance	Clear			-	-
2.	Odour	Odourless			Agreeable	Agreeable
3.	Turbidity (as N.T.U.)	0.1			1.0	5.0
4.	pH Value	6.98			6.5 to 8.5	No relaxation
5.	Chlorides (as Cl)	54			250	1000
6.	Nitrates (as NO ₃)	Nil			45	No relaxation
7.	Total Hardness (as CaCO ₃)	40			200	600
8.	Alkalinity (as CaCO ₃)	52			200	600
9.	Total Dissolved Solids	105			500	2000
10.	Iron (as Fe)	0.01			0.3	No relaxation
11.	Fluoride (as F)	0.1			1.0	1.5
12.	Other Tests (if any)	-				
13.						
14.						
15.						
16.						
17.						
18.						
19.						
20.						

- This report is restricted only for the Sample/s is Submitted to this Laboratory.

- This Sample/s is/are not Collected by this Laboratory.

Junior Scientific Officer
District Public Health Laboratory
A.nagar

REMARKS

A) Sample No. (s) 1 is/are potable / chemically fit for drinking purpose on the basis of analysed parameters only.

However, this / these water source/s can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

B) Sample No. (s) _____ Contains _____

However, if there is no any other alternate source available nearby then this / these water Source/s can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

C) Sample No. (s) _____ Contains _____

Hence, this / these water Source/s is / are chemically non-potable / unfit for drinking purpose on the basis of analysed parameters only.

HEALTH SERVICES

No. 198/72028

Date : 18/10/20

Forwarded With Compliments To : Tijameta English medium school
Parabaki Road, Sangamner, Dist - A. Nagar

With reference to letter No. : SEC 509 Dated : 09/07/20

Fees Rs. : 717/- / 940 Rs.

Receipt No. and Date : 4462875

 Junior Scientific Officer
District Public Health Laboratory
Ahilyanagar